




8700 Line Avenue, Shreveport, LA 71106 (800) 551-8633



## Popeye’s Site Inspection for FilterQuick 80/100/120 Installation

Successful installation of the new fryers rolling out to Popeye’s requires the site to meet specific requirements or be able to be retrofitted. The installation calls for two 3-vat units or one 3-vat and one 2-vat unit. Dimensions are above. Please provide the following data on the site:

Date:	Store Name:	Store Number:	Store Address:	
Store City:	Store State:	Store Phone:	Store Contact:	
FAS:	Tech:	Tech Phone:	FAS Address:	
FAS City:	FAS State:	FAS Phone:	FAS Email:	
Facility Requirements			Yes	No
Is there a dedicated 120 VAC 20-amp outlet for each fryer/system position (two banks of fryers will be installed)? Each fryer/system needs to be on a dedicated circuit with its own 20-amp breaker.				
Is there a 1" gas connection for each fryer position?				
Is there a 42" entry door to accommodate fryer entry to store?				
Is the aisle width and door opening adequate to remove the existing fryer?				
Are the hoods large enough to cover the fryer’s vats and flues?				
Can additional power outlets or gas lines be installed if necessary?				